



- NOTES:**
1. BUS CONSIST OF BOTH 3/4" COPPER SCH 40 AND SCH 80. SCH 40 AMPLACITY 765 AMPS, 17.5MW AT 40°C. SCH 80 AMACITY 875 AMPS, 20.0MW AT 40°C.
 2. FOR MATERIAL LIST, REFER TO SH F-6.
 3. FOR BUSWORK INSTALLATION INSTRUCTIONS, REFER TO TECHNICAL SPECIFICATIONS.

CVO Electrical Systems, LLC		BAR IS ONE INCH ON ORIGINAL DRAWING 0 IF NOT ONE INCH ON SCALES ACCORDINGLY.	
DRAWN: A. IRWIN	CHECKED:	PROJ. ENG.: J. WITKOWSKI	DATE: 3/10/05
5/07	REVISD RECORD DRAWING	5/05	REVISD RECORD DRAWING
3/05	RECORD DRAWING	3/05	RECORD DRAWING
BY APP'D	REVISION	CVOES CMF	CVOES CMF
MILTON-FREEWATER CITY LIGHT & POWER		FREEWATER SUBSTATION	
SUBSTATION PLAN VIEW		SHEET F-3	